

Office for Nuclear Regulation

An agency of HSE

Redgrave Court Merton Road Bootle Merseyside L20 7HS

Tel: 0151 951 4000 www.hse.gov.uk/nuclear

EDF AND AREVA UK EPR GENERIC DESIGN ASSESSMENT

GDA ISSUE

CLAIMS, ARGUMENTS, EVIDENCE TRAIL

GI-UKEPR-CI-03 REVISION 2

Technical Area	CONTROL AND INSTRUMENTATION		
Related Technical Areas	None		
GDA Issue Reference	GI-UKEPR-CI-03	GDA Issue Action Reference	GI-UKEPR-CI-03.A1
GDA Issue	The quality of the assessed Claims, Arguments and Evidence supporting documentation provided by EDF and AREVA requires revision and improvement.		
GDA Issue Action	<p>The CAE trail documentation provided by EDF and AREVA requires revision and improvement. EDF and AREVA to revise and improve the CAE trail documentation. In particular to:</p> <ul style="list-style-type: none">• review the UK EPR PCSR C&I sections and ensure that a clear CAE trail is provided for all key claims;• identify the evidence and related argument which demonstrates satisfaction of each of the ONR C&I SAPs. <p>For more guidance see: T13.TO1.01, T13.TO1.02, T13.TO1.03 (including all TOs referenced in the TO Table) and T13.TO2.01 to T13.TO2.43 in Annex 3; T16.TO2.27 in Annex 6; T17.TO2.26 in Annex 7; and T18.TO2.08 in Annex 8 of Step 4 C&I Division 6 Assessment Report, No. 11/022 Revision A (Draft).</p> <p>With agreement from the Regulator this action may be completed by alternative means.</p>		