



Chief Technical Officer
General Nuclear System Ltd. (GNSL)
Rex House
4-12 Regent St.
St. James's
London
SW1Y 4PE

Redgrave Court
Merton Road
Bootle
Merseyside
L20 7HS

Our Reference: 2021/56267

Unique Number: REG-GNS-0133N

21 July 2021

Closure of Regulatory Observation RO-UKHPR1000-0058 - Justification of the Structural Integrity Classification of the UK HPR1000 Main Steam Line and Associated Major Valves in the Safeguards Buildings.

Dear

I refer to Regulatory Observation RO-UKHPR1000-058 issued on 21 December Month 2018.

I am writing to confirm that:

- In response to all Regulatory Observation Actions, you have submitted the information committed to; and
- This information has been assessed by ONR and we judge that it provides an adequate response to our Regulatory Observation Actions.

On this basis, ONR confirms closure of Regulatory Observation RO-UKHPR1000-058.

It should be noted that whilst the specific requirements of this RO have been met by the submissions provided, the accepted structural integrity classification outcome for the Main Steam Line being a 'High Integrity Component' will mean it is subject to further assessment in accordance with RO-UKHPR1000-0046 'Demonstration that the Risks to High Integrity Components from Internal Hazards are Reduced to ALARP'.

A copy of this letter will be published on the ONR website in due course.

Yours sincerely,